



Commercial Diesel	Activated
Jet-A	Activated
n-Hexane	Did not Activate
Toluene	Did not Activate
Xylene	Did not Activate
Motor Oil	Activated
Gear Oil	Activated
Kerosene	Activated
Process Oil	Activated
"3 in 1" Oil	Activated
Soybean Oil	Activated
Corn Oil	Activated
Olive Oil	Activated


➤ **Safety disclaimer: This test procedure only addresses the issue of the method's ability to detect leaks. It does not test the equipment for safety hazards.**

---

**Certification of Results**

I certify that the liquid phase product detector was operated according to the vendor's instructions and that the evaluation was performed according to the standard EPA test procedure for liquid-phase out-of-tank product detectors except as noted on any attached sheets. I also certify that the results presented above are those obtained during the evaluation.

Thomas P. Muniz  
(printed name)

  
(signature)

8/16/2005  
(date)

Consultant  
(organization)

Berkeley, CA, 94705  
(city, state, zip)

(619) 459-4235  
(phone number)



Commercial Diesel	Activated
Jet-A	Activated
n-Hexane	Activated
Toluene	Activated
Xylene	Activated
Motor Oil	Activated
Gear Oil	Activated
Kerosene	Activated
Process Oil	Activated
"3 in 1" Oil	Activated
Soybean Oil	Activated
Corn Oil	Activated
Olive Oil	Activated


➤ **Safety disclaimer: This test procedure only addresses the issue of the method's ability to detect leaks. It does not test the equipment for safety hazards.**

---

**Certification of Results**

I certify that the liquid phase product detector was operated according to the vendor's instructions and that the evaluation was performed according to the standard EPA test procedure for liquid-phase out-of-tank product detectors except as noted on any attached sheets. I also certify that the results presented above are those obtained during the evaluation.

Thomas P. Muniz  
(printed name)

  
(signature)

8/16/2005  
(date)

Consultant  
(organization)

Berkeley, CA, 94705  
(city, state, zip)

(619) 459-4235  
(phone number)